742714


FOREIGN TECHNOLOGY DIVISION



THE VISCOSITY OF ISOBUTANE AT HIGH PRESSURES

by

N. A. Agayev and A. D. Yusibova



Approved for public release; distribution unlimited.

UNCLASSIFIED

	CONTROL DATA - R		a amount assess to along the de	
(Socially elecelitication of this. body of abonace and incommunity (Communication) Foreign Technology Division Air Force Systems Command U. S. Air Force		UNCLASSIFIED 38. GROUP		
REPORT TITLE	AM IITOU DDES	arma		
THE VISCOSITY OF ISOBUTANE	AT HIGH PRES		A	
Translation			······································	
Agayev, N. A. and Yusibova	ı, A. D.			
March 1969	74. TOTAL NO. 6	P PAGES	75. NO. OF REFS	
PROJECT NO. F-3615-71-C-1182 (71 Jan 01)		-24 -1 605-		
Approved for public releas	se; distributi	on unlin	nited.	
SUPPLEMENTARY NOTES		Technol	Logy Division on AFB, Ohio	
In literature there is a softhe viscosity of liquid parison of experimental fithat they differed from on a study was made of the viscosity of liquid that they differed from on a study was made of the viscosity of the liquid that they disconnected the liquid that they disconnected the liquid that they liquid they liqu	l and gaseous indings given ne another sub iscosity of li	isobutar in these stantial quid and	ne. The com- e works showed lly, therefore d gaseous iso-	

butane (including the line of saturation and the area close to the critical point) in the interval of pressures from 1 to 700 kg/cm(superscipt 2) and temperatures of 0-275 degrees C.

DD . FORM .. 1473

UNCLASSIFIED
Security Classification

EDITED MACHINE TRANSLATION

THE VISCOSITY OF ISOBUTANE AT HIGH PRESSURES

By: N. A. Agayev and A. D. Yusibova

English pages: 5

Source: Gazovaya Promyshlennost' (Cas Industry), Vol. 14, No. 3, 1959, pp. 41-43.

This document is a SYSTRAN machine aided translation, post-edited for technical accuracy by: Charles T. Ostertag.

UR/0492-69-014-003

Approved for public release; distribution unlimited.

THIS TRANSLATION IS A RENDITION OF THE ORIGI-NAL FOREIGN TEXT WITHOUT ANY ANALYTICAL OR EDITORIAL COMMENT. STATEMENTS OR THEORIES ADVOCATED OR IMPLIED ARE THOSE OF THE SOURCE AND DO NOT NECESSARILY REFLECT THE POSITION OR OPINION OF THE FOREIGN TECHNOLOGY DI-YISION.

PREPARED BY:

TRANSLATION DIVISION FOREIGN TECHNOLOGY DIVISION WP-AFB, OHIO.

FTD-MT- 24-1605-71

Date 21 Jan 19 72

U. S. BOARD ON GEOGRAPHIC NAMES TRANSLITERATION SYSTEM

Block A a B b C c A B B c C A B B C C A B B C C A B B C C A B C B C B C B C B C B C B C B C B C B C	Italic A a B b B c F a b E c XX 3 B H H H H H H H H H H H H H H H H H H	Transliteration A, a B, b V, v G, g D, d Ye, ye; E, e* Zh, zh Z, z I, i Y, y K, k L, l M, m	Block P c T y t x u u u u u u u u u u u u u u u u u u	Italic PCT y 中 x 4 y m 単 b H b B B B B B B B B B B B B B B B B B	Transliteration R, r. S, s T, t U, u F, f Kh, kh Ts, ts Ch, ch Sh, sh Shch, shch " Y, y E. e
м н Н н О о	ж н 0 о	N, n O, o	9 . 10 m	9 ; 10 %	E, e Yu, yu
Пп	Пи	P, p	R R	A x	Ya, ya

^{*} ye initially, after vowels, and after %, b; e elsewhere. When written as ë in Russian, transliterate as yë or ë. The use of diacritical marks is preferred, but such marks may be omitted when expediency dictates.

THE VISCOSITY OF ISOBUTANE AT HIGH PRESSURES

N. A. Agayev and A. D. Yusibova

In literature there is a series of works devoted to the study of the viscosity of liquid and gaseous isobutane [3-7]. The comparison of experimental findings given in these works showed that they differed from one another substantially, therefore a study was made of the viscosity of liquid and gaseous isobutane (including the line of saturation and the area close to the critical point) in the interval of pressures from 1 to 700 kg/cm² and temperatures of 0-275°C.

Unlike the procedure applied earlier [1] in this investigation liquid thermostatic control was used [8]. The temperature of the experiment was measured by a model resistance thermometer to within 0.02°C, pressure was measured by manometers of the type MP-60 and PM-600, class 0.05. The timing of escape was conducted automatically with a P-30 electric timer to within 0.1 s.

The main unit of the installation — a capillary viscometer — was made from "Supromaks" brand glass and it had the following geometric dimensions: diameter of capillary $d_{\rm H}=0.008818$ cm, length of capillary $t_{\rm H}=5.170$ cm, volume of the measuring balloon $V_{\rm H}=1.133$ cm³, the drop in the level of mercury in the viscometer $\Delta H_{\rm H}=5.743$ cm³.

Chromatographic analysis of the substance investigated by us showed that it contained 99.87% isobutane, 0.005% propane, and 0.08% n-butane.

Experiments were conducted based on isotherms with the temperature interval after every $10-25^{\circ}$, and in the area close to the critical point after $0.5-2.0^{\circ}$.

The step of pressure measurement in the beginning of every isotherm comprised 5-10 kg/cm², at a pressure above 100 kg/cm² the step was changed after every $50-100 \text{ kg/cm}^2$. In the area close to the critical point pressure on isotherms was changed with a step of $0.5-1.0 \text{ kg/cm}^2$.

The viscosity of isobutane was measured on the following isotherms: 0, 10, 25, 50, 75, 100, 111.67, 125, 130, 132.6, 134.98, 137, 140, 150, 175, 200, 225, 250, and 275. Here the limit of pressure measurement comprised 1-700 kg/cm². For the determination of the viscosity of liquid isobutane on the line of saturation and in the area close to the critical point measurements were made at pressures up to 50 kg/cm² on isotherms 131.2, 132.6, 133.3, 134.0, 134.5, and 135.5.

At the assigned temperature and pressure the measurements were made at each point 2-3 times; here the reproducibility of the experiments did not exceed 0.2%. A control measurement was conducted on the isobar 50 kg/cm 2 . The isobar data coincided with measurements on the isotherms with an accuracy of 0.2-3%.

The adjusted values of the viscosity coefficients of isobutane are given in Tables 1-3. The possible error of the experimental findings is estimated at $\pm 1\%$.

The diagram depicts the dependence of the excess viscosity $(\eta_{p,T}-\eta_{T})$ of isobutane on the density ρ for the limits of temperatures and pressures indicated in Tables 1-3. The values of density have been taken from works [9-10]. Values $(\eta_{p,T}-\eta_{T})$ at all temperatures and pressures are arranged in one general curve; deviation does not exceed $\pm 1.0\%$.

Table 1. Viscosity of isobutane (adjusted values), 10^{-5} N·s/m².

	(7) Testhepetype, °C																	
Su'd	•	10	25	50	75	100	110	125	830	134,58	137	140	130	175	200	225	250	273
1 5 10 115 20 25 30 35 5 40 50 60 70 250 300 250 300 500 500 600 700 700 700	19.95 20.08 20.22 20.30 20.62 20.65 20.74 21.27 21.52 21.78 22.32 22.85 24.68 30.06 32.66 33.32	17,80 17,93 18,05 18,19 18,32 18,46 18,57 18,63 18,70 19,23 19,46 19,73 20,70 21,45 22,66 23,85 25,03 27,42 29,71 32,06	15.20 15.33 15.46 15.58 15.58 15.94 15.96 16.31 16.56 16.31 17.04 17.53 17.98 19.76 20.84 21.93 24.10 26.26 28.40	11,91 12,04 12,129 12,38 12,43 12,70 12,70 13,44 13,89 14,31 15,98 16,95 17,92 19,63 21,63 22,45	14,03 14,92 16,63 18,25 19,80	0.924 0.944 0.994 0.992 6.725 6.951 7.320 7.390 7.496 7.810 8.350 8.350 8.350 10.970 11.870 12.770 11.870 12.770 15.750 15.750 18.370	6,583 6,947 7,252 7,533 7,801 8,322 8,773 9,400 10,270	1.020 1.048 1.048 1.145 1.145 5.200 5.200 5.200 5.200 6.444 6.746 7.750 8.410 9.374 10.220 10.990 12.450 13.8050	5,299 5,730 6,102 6,410 6,983 7,470 8,150 9,900 12,150 13,480	1,023 1,043 1,070 1,104 1,159 1,257 1,514 2,360 4,875 5,762 5,771 6,136 6,675 7,850 8,857 1,420 11,910 13,180 14,380	1,027 1,048 1,079 1,109 1,162 1,255 1,462 1,650 3,660 7,730 8,730 10,300 11,750 13,250	1,033 1,054 1,082 1,114 1,166 1,252 1,419 1,537 2,754 4,429 5,041 5,488 5,810 6,397 6,890 7,580	1,181 1,248 1,363 1,421 1,590 3,227 4,199 4,793 5,823 6,321 7,030 8,032 8,878 9,603 11,030 11,3400	1,113 1,158 1,187 1,226 1,272 1,334 1,360 1,422 1,735 3,107 3,675 4,508 5,075 6,822 7,651 8,415 9,781 12,120	110.910	1,224 1,245 1,267 1,291 1,313 1,316 1,316 1,316 1,416 1,558 1,770 2,270 2,270 2,270 3,270 3,980 5,980 6,600 7,750 8,880 9,870	1,280 1,301 1,323 1,343 1,367 1,348 1,416 1,440 1,584 1,710 2,910 2,470 2,910 3,500 4,400 5,170 5,880 7,005 8,150 9,150	1,356 1,375 1,395 1,414 1,453 1,470 1,575 1,720 2,310 2,310 2,310 3,950 4,650 5,295 6,450 7,520 7,550

KEY: (1) Temperature, °C; p, kg/cm².

Table 2. Viscosity of isobutane (adjusted values) 1.0^{-5} N·s/m².

(2)	(1) Температура, ⁴ С							
p, nl'/cm	131.2	132,0	133,0	134,0	134,5	135,5		
35 36 36,2 37 37,5 38 39 40 45	3,935 4,100 4,130 4,225 4,282 4,345 4,450 4,545 4,915 5,200	3,783 3,965 3,995 4,105 4,180 4,230 4,310 4,433 4,830 5,130	3,530 3,770 3,815 3,910 4,015 4,080 4,200 4,300 4,725 5,010	3,150 3,525 3,725 3,815 3,900 4,030 4,145 4,615 4,955	3,330 3,585 3,700 3,790 3,940 4,070 4,570 4,910	3,900 3,350 3,560 3,730 3,900 4,455 4,825		

KEY: (1) Temperature, °C;

(2) p, kg/cm^2 .

Table 3. Viscosity of isobutane on the line of saturation (adjusted values) 10^{-5} N·s/m³.

	t _g , •C	1/3 Hens	η', (1) (жалкость)	n; (62)
	0 10 20	1,585 2,223 3,039	19,700 17,720 16,000	0,699 0,725 0,731
	20 30 40 50 60	4,073 5,356 6,927 8,809	14,400 12,98) 11,700 10,58)	0,778 0,806 0,836 0,866
	70 80 90	11,06 13,71 16,79	9,52) 8,530 7,503	0,900 0,937 0,979 1,030
!	100 110 120 123	20,33 24,38 28,97 31,38	6,721 5,860 4,952 4,375	1,100 1,216 1,312
	130 132 135	34,13 35,25 37,22	3,830 3,575 2,360	1,423 1,615 2,300

KEY: (1) (liquid); (2) (gas);
(3) p, kg/cm².




Figure: Dependence of $(n_{p,T}-n_{T})$ on density for isobutane.

KEY: $(1) s/m^2$;

- (2) saturation line;
- (3) g/cm.

Data found in the literature for the gaseous state at atmospheric pressure [4] and data given in work [3] for liquid isobutane on the saturation line are respectively 2 and 9% higher than that obtained by us. It should be noted that the comparative analysis of the data on the viscosity of liquid saturated hydrocarbons of a normal series and their isomers at atmospheric pressure showed that the viscosity of isomers as a rule is less. And only the data given in work [3]

The latter gives grounds to doubt their reliability. are an exception.

The comparison of data on the viscosity of isobutane at increased temperatures and pressures shows that the data of the authors of work [6] are 8% lower than ours. The divergences of our data and data of work [7] on all isotherms do not exceed 2.5%.

The sufficiently satisfactory coincidence of our data with the data of work [7], obtained by the capillary method, and the large divergence with the data obtained by the method of the rolled ball [6], again confirms the inadequacy of the method of the rolled ball, which was already indicated earlier [1, 11].

BIBLIOGRAPHY

- [1] Голубев И. Ф., Агяев И. А. Вязкость предельных углеводородов. Изд. «Азорнешр», 1963.
- [2] Агаев Н. А., Юсибова А. Д. Вязкость изооктана при висоних давлениих и различных температурах. «Газовая промышленность», № 6, 1906.
- [3] Lipkin M. R., Davidson J. A., Kurtz S. S. Ind. Eng. Chem., Ind. Ed., v. 34, N 8, 1942.

- NO, 1932.

 [4] Titari T. Bull. Chem. Soc. Japan, v. 5, N 3, 1930.

 [5] Jshida J. Phys. Rev. v. 21, 1923.

 [6] Sago B. H., Jale W. D., Laccy W. N. Ind. Eng. Chem., Ind. Ed., v. 31, N 2, 1939.

 [7] Gonzalez M. H. Lee A. L. I of chemical and engineering date, v. 11, N 3, 1966.

 [8] Araea H. A., Юсчбова А. Д. «Теплоэпергетика», № 9, 1907.

- [9] Sage B. H., Laccy W. H. Ind. Eng. Chem., Ind. Ed., v. 130, N 6, 1930.
 [10] Физико-химические свойства индивидуальных углеводородов. FHTH нефтиной и горногопливной интературы, 1947.
 [11] Голубев И. Ф. Визкость газов и газовых смесей. Физиатия, 1950.

(Azerbaydzhan Scientific-Research Institute of Power Engineering imeni I. G. Yes'mana [AzNII]).